



**DATE:** November 14, 2016

**To:** All Prospective bidders

**Re:** Development of Technically Based Local Limits for City of Coachella Sanitary District (CSD)

### ADDENDUM No. 1

#### Questions

1. Approximately how much CSD historical monitoring data are available?
  - *At least 5 years*
2. What is the format of the CSD historical monitoring data for the treatment plant, industrial users, and domestic wastewater? For example, will the data be provided in an Excel spreadsheet?
  - *Excel format is available*
3. Are all existing data available in excel format?
  - *See reply above*
4. How recently was uncontrollable/commercial sampling and analysis performed?
  - *2005 was the last time for uncontrollable/commercial sampling*
5. Can we obtain a list of the City of Coachella's current local limits?
  - *Yes, see attached*
6. Is the City planning to recycle the effluent for irrigation or for other purposes?
  - *Yes*
7. In anticipation of the local limits evaluation, has the City conducted any additional sampling beyond the requirements of the discharge permit?
  - *No*
8. Has any additional sampling for Bis(2-ethylhexyl) phthalate been conducted?
  - *These samples are collected monthly at the WWTP*
9. Are copies of the past two industrial pretreatment annual reports available?
  - *No, the City does not have a formal pretreatment program*
10. Are copies of previous local limits evaluations available?
  - *Yes- a copy will be made available to you if your firm is chosen to complete the project*
11. How many Categorical Industrial Users are under the City's jurisdiction?
  - *None- there are two CIUs that have evaporation ponds and or are on septic*
12. How many Non-categorical Significant Industrial Users are under the City's jurisdiction?
  - *None*
13. Has there been any permit violations related to Industrial Users in the last 5 years?
  - *No*

### ADDENDUM No. 1

Addendum No.1

**Development of Technically Based Local Limits for City of Coachella Sanitary District (CSD)**

November 14, 2016

Page 2 of 2

*The Bidder is hereby notified; Addendum No. 1 must be acknowledged as stipulated under Section “INSTRUCTIONS TO BIDDERS”, ADDENDA OR BULLETINS, and submitted as part of the Bid. Failure to do so shall result in the City designating said bid as “Non-Responsive”.*

**APPROVED:**

Berlinda Blackburn

Berlinda Blackburn

Environmental/Regulatory Programs Manager

**BIDDER ACKNOWLEDGMENT:**

\_\_\_\_\_  
Signature acknowledging receipt of Addendum No. 1

\_\_\_\_\_  
Printed Name & Date

\_\_\_\_\_  
Company

**END OF ADDENDUM No. 1**

**This addendum No. 1 shall be signed by the Bidder and returned together with the Bidder’s sealed Bid Proposal.**

<b>SUMMARY OF RECOMMENDED LOCAL LIMITS</b>		
<b>Pollutant</b>	<b>Local Limit</b>	<b>Recommendations (1)</b>
<b>Inorganics</b>		
copper	0 mg/L	Institute BMPs
cyanide	0 mg/L	Institute BMPs
mercury	0 mg/L	Institute BMPs
selenium	0 mg/L	Institute BMPs
zinc	0 mg/L	Institute BMPs
<b>SEMI VOCs</b>		
Bis (2 hexylethyl) phthalate	0 mg/L	Institute BMPs
<b>PESTICIDES</b>		
4,4 DDE	0 mg/L	Institute BMPs
4,4 DDT	0 mg/L	Institute BMPs
Heptachlor epoxide	0 mg/L	Institute BMPs
<b>GENERAL CHEMISTRY</b>		
BOD5	286 mg/L	Institute BMPs
TSS	159 mg/L	Institute BMPs
TDS	3,000 mg/L	Institute BMPs

Notes:

- (1) Proposed local limits are based on the proposed NPDES permit renewal that is scheduled to be adopted on June 29, 2005.